eco-INSTITUT, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

eco-INSTITUT Germany GmbH
Laborprüfung
Laboratory testing

Dorring GmbH
Frau Tatjana Brendel
Siemensstraße 16
DE 75210 Keltern

Dear Ms. Brendel,

the testing results of the product **Mobile Trennwand | Dorrflex**, commissioned by **Dorring GmbH**, comply with the following requirements:

LEEDv4.1 Rating System for projects outside of the U.S. – EQ Credit: Low-Emitting Materials

LEEDv4 Rating System for projects outside of the U.S. - EQ Credit: Low-Emitting Materials

Testing standard: EN 16516:2017+A1:2020				
Compliance: AgBB Testing and Evaluation Scheme (2018-2024)				
Product category: Wall panels		Loading factor: 1.0 m^2/m^3 for wall products		
Application quantity: not applicable				
Requirements 28 days after test chamber loading:				
Formaldehyde	Sum of R ratios	Sum VOC w/o LCIs	TVOC	**Requirements hold**
≤ 10 µg/m³	≤ 1	≤ 100 µg/m³	≤ 1000 µg/m³	**Yes**
Range of TVOC acc. to DIN ISO 16000-6: ≤ 0.5 mg/m³				

Cologne, 02/03/2026

Manuel Hiertz,
(Project management)